



ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ, ਜਲ ਸਪਲਾਈ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ
ਉਪ ਮੰਡਲ, ਝੁਨੀਰ ਐਟ ਮਾਨਸਾ


Website:-www.pbdwss.gov.in., E-Mail:-subdivisionjhuniratmansa@gmail.com

No:- 628

Date:- 12/8/2024

Certificate regarding safe drinking water and sanitary condition

Certified that Sahibzada Jujhar Singh Public Senior Secondary School, Kot Dharmu Tehsil & Distt Mansa, Punjab was visited and inspected by Sh. Jagjit Singh, Junior Engineer and found that Sahibzada Jujhar Singh Public Senior Secondary School, Kot Dharmu Tehsil & Distt Mansa, Punjab has safe drinking facilities as per report No. DWTL/MNS/2324/00113 dated:-13.03.2024 by District Water Testing Laboratory Mansa and maintaining the hygienic sanitation condition in the school campus.


Sub Divisional Engineer
W/S & Sanitation Sub Division
Jhunir At Mansa

DISTRICT WATER TESTING LABORATORY, MANSA

Water Supply and Sanitation division no. 1 Complex, Jawaharke, Mansa, District Mansa
dwtlmansa@gmail.com

To,

SAHIBZADA JUJHAR SINGH PUBLIC SEN.SEC.SCHOOL
VILLAGE KOT DHARMU DISTRICT MANSA


No.: DWTL/MNS/2324/00113 Dated : 13/03/2024

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. SJSPS/2023-24/4650 Dated: 07/03/2024

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 07/03/2024. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Mansa

D/A : Test Report



**Authorized Signatory
For, District Water Testing Laboratory
Mansa**



TEST REPORT

Name & Address of Customer : SAHIBZADA JUJHAR SINGH PUBLIC SEN.SEC.SCHOOL VILLAGE KOT DHARMU DISTRICT MANSA		Customer Reference No.	No : SJS/2023-24/4650 Dated : 07/03/2024	
		Sample Submitted by	Sh. SUKHWINDER SINGH	
		Date of Sample Receipt	07/03/2024	
		Analysis Starting Date	11/03/2024	
		Analysis completion Date	12/03/2024	
Discipline : Chemical Testing		Group: Water		
ULR No.:	TC00012400000037F	Sample Type :	Water	
Test Report No.:	DWTL/MNS/2324/00113	Date of Issue :	13/03/2024	
Registration no.:	DWTL/MNS/REG2324/00554	Condition of Sample :	Unsealed	
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	500 ml / Transparent Glass Bottle	
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	VILLAGE KOT DHARMU DISTRICT MANSA / NA	
Village :	Kot Dharmu	Habitation :	Kot Dharmu	
Block:	Jhunir	District :	Mansa	
Latitude :	Not Mentioned	Longitude:	Not Mentioned	

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.01	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	03	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	250	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.71	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity	40	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness	28	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2019) EDTA Method
9	Calcium	06	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium	03	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride	22	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Komal Sharma

Ms. Komal Sharma
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory
Mansa

----- End of the Test Report -----